



ADDENDUM NO. 2

for

P7161-0132-06 U – MOOSONEE AIRPORT - REHABILITATION OF RUNWAY 06-24 & TAXIWAY ALPHA

The Contract Documents for this work are revised as noted herein.

Receipt of this Addendum must be acknowledged when submitting your Tender.

.1 QUESTIONS AND ANSWERS

Q1: We would like to request for an extension of time on the closing date for Moosonee Airport Improvements.

A1: There will be no extension of time to the closing date of 11:00 a.m. local time on Friday, June 24, 2016. However, full tender package will be accepted by email submission prior to bid closing date to the Town Clerk Treasurer's email address: spetten@moosonee.ca. Please include in the subject header of the email "Tender Package Moosonee Airport Improvements".

Emails will not be opened until after the tender closing date. **Complete hard copies of the original full tender package** shall be received by the Town of Moosonee within **7 days** after bid closing.

Q2: Is it possible to email the bid prior to bid closing; and follow up with a hard copy to you or to Moosonee?

A2: See the response A1 above.

Q3: What are the plans for the electrical trench excavation? 10:1 taper with Granular A backfill within the paved section or a straight trench?

A3: Straight trench

END OF ADDENDUM NO. 2

_